



Town of Williston  
7900 Williston Road  
Williston, VT 05495

1763

Public Works  
(802) 878-1239

## MEMORANDUM

---

To: Ken Belliveau, Town Planner  
From: Lisa Sheltra, PW Assistant Director  
CC: Bruce K. Hoar, Public Works Director  
Date: December 11, 2017  
RE: DP 18-05, BEVS, Lot 26 Production Park

Public works has completed a technical review of the above referenced plan. Project shall conform to the latest Public Works Standard Specifications. As-Built plans and Engineering Certifications are required at the completion of the project, prior to Certificate of Occupancy (CO). Please provide a **written response** to the following items prior to receiving approval for the project:

1. We have three pages that are labeled D-3 Civil Details. Are we missing other detail sheets?
2. There are two manholes labeled SMH#1
3. Straighten out the water service, no need for that many bends
4. Is the existing sewer stubbed out or will there be a core in the existing manhole?

The applicant must obtain the signature of DPW staff on the Final plans Checklist showing that the final plans address the above comments prior to submitting final plans to the Planning and Zoning staff for review and approval.